

Adams-Cedar Hill Water System

604 Keysburg Road – Adams, TN 37010
Phone: (615) 696-2266, Fax: (615) 696-0667

FIELD OFFICE
RECEIVED

November 21, 2014

Mrs. Ann Morbitt
Department of Environment and Conservation
Division of Water Resources
Nashville Environmental Field Office
711 R.S. Gass Blvs.
Nashville, TN 37216

RE: Sanitary Survey
Adams-Cedar Hill Water System
PWSID# 0000001, Robertson County

Dear Mrs. Morbitt:

Thank you for your report on our Sanitary Survey conducted on October 9-10, 2014. We have made several changes and are in the process of implementing new procedures to address the issues you found.

- Item 1. All Distribution system operators have been made aware of this error and will be trained on the correct Bacteriological sampling methods after a line repair. Billy Vogle, the Distribution System Manager will ensure this does not happen again.
- Item 2. On November 17, 2014 a representative from TAUD assisted the system in updating its source water protection plan and helped train Mr. Ayres on how to keep this file updated in the future.
- Item 3. Mr. Ayres, the Chief Water Plant operator has made changes in the way record keeping is done so as to make sure this does not happen again and MORs will arrive in a timely manner.

Regarding items from the Compliance Evaluation Inspection of the waste water facilities:

- Item 1. We appreciate Mr. Smithson's assistance with this issue. Neither the system nor our lab we use to test discharge samples were aware of a need to test for Iron because we are a surface water plant and do not add any Iron to our water in the treatment process.

Adams-Cedar Hill Water System

Item 1 continued.

We have notified our lab that Iron sampling will begin immediately for any future discharge samples. I received confirmation today from Mr. Shinbaum at Environmental Science Technologies that Iron testing is confirmed for all our discharge samples.

The Adams-Cedar Hill Water System would like to compliment Mr. Smithson, he was a pleasure to work with and we appreciate his professionalism and good work.

If you have any questions, please feel free to contact me at (615) 696-2266.

Sincerely,

A handwritten signature in black ink, appearing to read "R. Stephen Ayres", with a long, sweeping horizontal stroke extending to the right.

Stephen Ayres
Chief Operator
Adams-Cedar Hill Water System

Cc: Mr. Jeff Smithson
Department of Environment and Conservation
Division of Water Resources
Nashville Environmental Field Office
711 R.S. Gass Blvs.
Nashville, TN 37216